

**METER PITS FOR DOMESTIC SERVICES  
CITY OF SYRACUSE, NEW YORK**

METER PITS SHALL BE AS INDICATED BELOW OR APPROVED EQUAL

THE FOLLOWING OPTIONS ARE REQUIRED FOR INSTALLATION DURING CONNECTION TO THE CITY OF SYRACUSE WATER SYSTEM:

DESCRIPTION	Up to 1-inch meter		Up to 2-inch meter		
	FORD	MUELLER	FORD	MUELLER	
		THERMAL -COIL			
<b><u>PIT SETTER</u></b>					
PIT SETTING:	Single Meter	PD	CS	PM	VS
INLET VALVE:	Angle Ball	B	F	B	F
OUTLET VALVE:	Angle Ball	B	F	B	F
METER SIZE:		4	330	7	550
INLET:	Male IP	2	H-15450, 1"	8	H-15450, 2"
OUTLET:	Male IP	2	H-15450, 1"	8	H-15450, 2"
PIT DIA.:		20-in.	18-in.	36-in.	27-in.
PIT DEPTH:		54-in	54-in	54-in	54-in
BOX BOTTOM:	Less Bottom				
ORDER CODE:		PDBB-422-20-54		PMBB-788-36HB-54	
<b><u>PIT COVER</u></b>					
LOCK TYPE	Side Lock		S		S
BOX COVER:	Double Lid W/ Touch Read	W3H-T	282925 w/ Touch Read & Insulation Pad	MC-36-MB-T	700098, 282925 w/ Touch Read & Insulation Pad
ADAPTER	(to fit meter as sized by SWD)	A14,A34	H-10879:5/8x3/4x1 3/4x1	A47,A67	

FORD or MUELLER PITS AND COVERS ARE AVAILABLE LOCALLY FROM THE FOLLOWING DISTRIBUTERS:

BLAIR SUPPLY CO.	(585) 436-9624	FAX:	(585)-436-1907
RAMSCO SUPPLY CO.	(800) 832-7473		
VELLANO BROS. INC.	(315) 455-2995		
MARTISCO CORP.	(315) 471-3181		